

NOTICE



DRINKING WATER

Recent testing has shown that the SODIUM content of the water at Admaston PS is above the recommended level of 20 mg/L.

The SODIUM level of this water is currently 166 mg/L

**Please consult your physician with any concerns regarding your SODIUM intake.
Thank you**